



NATIONAL GUARD
PRODUCTS

Strike Shim

9275 - Fits 4-7/8" 'ASA' Strike Plate



Material

Steel

- UL Certified Miscellaneous Fire Door Accessory for excessive door and frame clearances, measuring up to 5/16"
- 90 minute rated UL10B and UL10C wood or hollow metal fire doors
- NGP 9200 Intumescent Seal excessive clearance solution is also required where excessive clearance occurs at jambs and head on 20 minute fire doors
- NGP 9400 Intumescent Seal, 9945 Steel Stop Extender, 5075 Self-Adhesive Seal excessive clearance solutions are also required where excessive clearance occurs at jambs and head on 90 minute fire doors

Finishes

Gray

Project:

Submitted by:

Date:

Notes:

