



## Gap Solution for Excessive Fire Door Top Clearance — 90 Minute

UL Certified Solution for Fire doors with Excessive Door Top Clearances up to 1/2"

### NGP-Edge® Intumescent Door Cap

Patent Pending

**9990**



90 minute rated UL10B and UL10C wood or hollow metal fire doors

Certified for use on doors with Concealed Vertical Rod Exit Devices or Automatic Flush Bolts, refer to Installation Instructions.

Non-Handed

Available in 36", 48" lengths

End caps furnished standard

#6 x 3/4" Stainless Steel SMS furnished

Brushed stainless steel

*Product consists of:*

- #304 Brushed Stainless Steel Flat Plate - pull side
- #304 Brushed Stainless Steel Intumescent Cap - push side
- #304 Brushed Stainless Steel End Caps

*No need to move hardware at the top of the door.*

*Works on doors with Parallel arm closers.*

